Datasheet Ardbox Analog HF+ MODBUS & LoRa



Industrial Shields

Technical Features CONECTABLE PLC ARDUINO 24Vcc ARDBOX

MODEL TYPE	Ardbox Analog	
Input Voltage	12 to 24Vdc (Fuse protection (2.5A) Polarity protection)	
Input rated voltage	24Vdc	
Rated Power	30 W	
I max.	15A	
Size	100x45x115	
Clock Speed	16MHz	
Flash Memory	32KB of which 4KB used by bootloader	
SRAM	2.5KB	
EEPROM	1KB	
Communications & Accessories	LoRa - I2C - USB - RS485 - RS232 - SPI	
USB consideration!	Only for uploading or debugging. NOT connected as a serial Cannot be working in a final application	

INPUTS (x8)

An/Dig Input 10bit (0-10Vcc) - (x7)	0 to 10Vac Input Impedance: 39K Separated PCB ground Rated Voltage: 10Vac 7 to 24Vdc I min: 2 to 12 mA Galvanic Isolation Rated Voltage: 24 Vdc
Digital Input (24Vcc) - (x1)	7 to 24Vdc I min: 2 to 12 mA Galvanic Isolation Rated Voltage: 24 Vdc

Expandability

I2C : 127 elements - ModbusRTU RS485: 32 elements - LoRa

OUTPUTS (x9)

Analog Output 8bit	0 to 10Vac
(0-10Vcc) - (x6)	I max: 20 mA
* The Analog outputs can	Separated PCB ground
also work as Digital outputs	Rated Voltage: 10Vac
Digital Isolated Output (24Vcc) - (x3)	5 to 24Vdc I max: 70 mA Galvanic Isolation Diode Protected for Relay Rated Voltage: 24Vdc
PWM Isolated	5 to 24Vdc
Output 8bit (24Vcc)	I max: 70 mA
- (x6)	Galvanic Isolation
• The PWM outputs can also	Diode Protected for Relay
work as Digital outputs	Rated Voltage: 24Vdc

015001001200




Original **Arduino Mega** included

General Features				
Power supply voltage	DC power supply	12 to 24Vdc		
Operating voltage range	DC power supply	11.4 to 25.4Vdc		
Power consumption	DC power supply	30 W MAX.		
External power supply	Power supply voltage	24Vdc		
	Power supply voltage	700Ma		
Insulation resistance	20MΩ min.at 500Vdc between the AC terminals and the protective earth terminal.			
Dielectric strength	2.300 VAC at 50/60 Hz for one minute with a leakage current of 10mA max. Between all the external AC terminals and the protective ground terminal.			
Shock resistance	80m/s2 in the X, Y and Z direction 2 times each.			
Ambient temperature (operating)	0° to 60°C			
Ambient humidity (operating)	10% to 90% (no condensation)			
Ambient environment (operating)	With no corrosive gas			
Ambient temperature (storage)	-20° to 60°C			
Power supply holding time	2ms min.			
Weight	350g max.			

Pinout





Industrial Shields

Performance Specifications

1		
Arduino Board	Arduino Leonardo	
Control method	Stored program method	
I/O control method	Combination of the cyclic scan and immediate refresh processing methods.	
Programming language	Arduino IDE. Based on wiring (Wiring is an Open Source electronics platform composed of a programming language. "similar to the C")	
Microcontroller	ATmega32U4	
	http://arduino.cc/en/Tutorial/HomePage	

Install Arduino IDE and the Industrial Shields boards	Warnings
The steps to follow to install our equipment's to Arduino IDE are:	Unused pins should not be connected. Ignoring the directive may damage the controller.
\cdot Open the Arduino IDE, versión 1.8.0 or superior. If you don't have it yet , you can download here	Before using this product, it is the responsibility of the user to read the product's User Guide and all accompanying documentation.
https://www.arduino.cc/en/Main/Software .	Industrial Shields PLCs must be powered between 12Vdc and 24Vdc. If a higher voltage is supplied to the equipment can suffer irreversible damage.
Press the "Preferences" option to "File" menu and open the preferences window.	Maintenance must be performed by qualified personnel familiarized with the construction, operation, and hazards involved with the control.
• In the text box "Additional boards manager URLs", add the direction: http://apps.industrialshields.com/main/arduino/boards/package_ind	Maintenance should be performed with the control out of operation and disconnected from all sources of power.
 ustrialshields_index.json Close the preferences window with the "OK" button. 	The Industrial Shields Family PLCs are Open Type Controllers. It is required that you install the M-Duino PLC in a housing, cabinet, or electric control room. Entry to the housing, cabinet, or electric control room should be limited to authorized personnel.
• Click on "Tools" menu, and open the "Boards" submenu, and click the "Boards Manager" option, to open the Boards Manager window.	Inside the housting, cabinet or electric control room, the Industrial Shields PLC must be at a minimum distance from the rest of the components of a minimum of 25 cm, it can be severely damaged.
\cdot Search "industrial shields" to the search filter and select to the list and click "Install"	Failure to follow these installation requirements could result in severe personal injury and/or property damage. Always follow these requirements when installing M-Duino family PLCs.
• Close the "Boards Manager". Once it is performed that steps, you are available to select each PLC that you wish to work on "Tools" -> "Boards" : M-Duino	In case of installation or maintenance of the M-Duino please follow the instructions marked in the Installation and Maintenance section on the User Guide.
To get more information: https://www.industrialshields.com/first-steps-with-the-industrial- arduino-based-plc-s-and-the-panel-pc-s-raspberry-pi-based#boards	Do not disconnect equipment when a flammable or combustible atmosphere is present. Disconnection of equipment when a flammable or combustible atmosphere is present may cause a fire or explosion which could result in death, serious injury and/or property damage.

Symbology

бушовобу		roomiourbupport
	Indicates that the equipment is suitable for direct current only; to identify relevant terminals	You can contact with us using the best channel for you: support@industrialshields.com
\sim	Indicates that the equipment is suitable for alternating current only; to identify relevant terminals	
Г. П.	To identify the control by which a pulse is started.	www.industrialshields.com
	To identify an earth (ground) terminal in cases where neither the symbol 5018 nor 5019 is explicily required.	Visit our Blog, Forum orTicketing system
\otimes	To identify the switch by means of which the signal lamp(s) is (are) switched on or off.	34 644 927 900
CE	CE marking indicates that a product complies with applicable European Union regulations	Use our chat service
⚠	Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury	Check the user guides
4	To indicate hazards arising from dangerous voltages	Visit our Channel